

## Questions for Paving Bid

1. What is the approximate start date for this contract?

Will be discussed with the contractor awarded the contract at the pre-construction meeting

2. Who will be responsible for Asphalt Testing?

Asphalt shall be manufactured according to approved by MDOT SHA mix designs and will be tested in the asphalt supplier plant lab.

3. Who will be responsible for final striping?

City Street Department will be responsible for the final striping

4. For item no. 5, what size tape will be used for temp. traffic control tape?

Tape should be 4 inch wide

5. Is there a preference of sweeper to be utilized for the project?

Sweeper should be equipped with dust water control and container for vacuum dust.